



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/01/2026

Area: CHP

Equipment	Job
R 1	8 nos lamp fixtures removed and repaired, made ready for use
Coal complex	Rooms cleaning done
RECL 1	9 nos 30W lamps replaced
CC 38 S1	LT end limit striker welded and tested
CC 37,39,40,42,45,,112,SCR 2,6,7,8	Running inspection was done
LC 15 to Processor B	Prophibus cable 2 lines laid through conduit
CC 28,109,28TT,39,SCR 6	PPM was done