



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/02/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-13	Reported stopping on belt sway	CO-16 BSS bypass wire loose at I/O rack	11:50:00	12:00:00	
2	CHP	CC-31 SCR-4	Luff not taking place	Fuse replaced at I/O rack and tested okay	06:45:00	07:00:00	
3	CHP	CC-31 SCR-4	Reported no operations taking place	Wrong complaint	06:40:00	07:17:00	
4	CHP	Cc-216	Reported tripped	OLR acted.Reset done	07:10:00	07:25:00	
5	CHP	CC-31	Reported tripped	OLR acted.Reset done	07:10:00	07:25:00	
6	CHP	Cc-105 SCR-10	PCRD cable found in unwinded condition on ground	Guide adjustment done and cable winded properly	09:30:00	09:50:00	
7	CHP	Cc-51	MPD tripped	Reset done(2 times)	10:30:00	13:35:00	
8	CHP	Cc-54	Reported tripped	OLR acted.Reset done(2 times)	11:45:00	11:52:00	
9	IOSA	OC-25A	Reported CJD not resetting	Checked and found adjustment problem.Bypassed and given clearance for running	08:35:00	08:50:00	Rectified by instrumentat ion and kept in line at 9.30am