



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 04/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29 WBR	DOWN LIMIT ACTED	LUFF UP DONE THEN OK	19:40:00	19:55:00	
2	OHP	CO-67	TRIPPED ON OLR	RESET DONE	19:45:00	19:55:00	
3	OHP	WBR ON CO -25	YARD ZSS CAGE TIED WITH ROPE DURING BELT WORK	MADE FREE	20:40:00	20:50:00	
4	CHP	CC-37 SCR-3	BC TRIPPED ON OLR	RESET DONE	17:20:00	17:30:00	
5	CHP	CC-32	DRIVE END CHUT SENSOR CABLE GOT CUT	REJOINED	18:45:00	19:00:00	
6	CHP	CC-39 SCR-6	SLEW NOT WORKING	MATERIAL JAMMING ... INFORMED OPERATION	18:45:00	18:55:00	
7	CHP	CC-223	DRIVE TRIPPED ON OL	RESET DONE	19:40:00	19:50:00	
8	CHP	CC-32 SCR-5	LT NOT WORKING .. PCRD OVER TENSION	RELEASED AND CABLE ADJUSTED	19:10:00	19:25:00	
9	WT	OT-4	D-1 TRIPPED ON PGF-4 FAULT	RESET DONE	19:25:00	19:30:00	
10	IOSA	IOSA	COMMUNICATION PROBLEM	POWER RECYCLED IN OM-4 ; LC-3 ;OM-1 LC-1	16:25:00	17:35:00	