



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/05/2025

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment        | Problem                                                       | Action                      | From                 | To                   | Remarks |
|-------|------|------------------|---------------------------------------------------------------|-----------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 26            | OLR ACTED                                                     | RESET                       | 01:00:00<br>22:30:00 | 01:10:00<br>22:40:00 |         |
| 2     | OHP  | BRC ON<br>CO 33M | B/C NOT RUNNING E/STOP ACTED                                  | RELEASED                    | 00:00:00             | 00:15:00             |         |
| 3     | CHP  | CC 39            | ZS PROBLEM CHECKED BELT OFF<br>CENTRING                       | IN FORMED TO MECH           | 05:00:00             | 05:15:00             |         |
| 4     | CHP  | CC 35 SCR<br>2   | LT NOT TAKING PLACE O/T ACTED                                 | OT released                 | 01:00:00             | 01:20:00             |         |
| 5     | CHP  | CC 38 SCR<br>3   | LT not taking place, drive trips in overload                  | reset it done               | 00:14:00             | 00:40:00             |         |
| 6     | CHP  | CC 38 SCR<br>3   | luffing down not working,full jamming in limit<br>switch area | informed operation          | 00:30:00             | 00:40:00             |         |
| 7     | WT   | OP 10            | no fwd movement , OT 2 LS2 fb not came                        | clamp de clamp done than ok | 23:30:00             | 23:35:00             |         |