



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/04/2025

Area: IOSA

Equipment	Job
OC-23A	FILED DEVICES CABLE TRAY GOT RUSTED AND BROKEN. CABLE DRESSING DONE AFTER CABLE TRAY WELDING.
MISC	BASE FRAME FABRICATION IS IN PROGRESS FOR UPS SYSTEM
UPS	BATTERIES TOP UP DONE , LINKS CONNECTED AND VOLTAGES CHECKED.