



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 12(B)	not running,MPCB tripped	made it on	08:50:00	08:55:00	
2	OHP	CO 12(C)	mpcb tripped due to jamming	made it on0940	09:40:00	09:45:00	
3	OHP	CO 58 (B)	mpcb tripped due to jamming	made it on	12:45:00	12:49:00	
4	OHP	BRC on CO 32	LT not working,due to brake mpcb tripped	made it on	12:55:00	13:10:00	
5	OHP	CO 29	olr acted	reset	10:30:00	10:35:00	
6	OHP	CO 58(B)	olr acted	reset	12:56:00	13:01:00	
7	CHP	CC 107	motor not running,zss acted belt slipping	informed to operation	08:30:00	08:40:00	
8	CHP	CC 33 SCR5	b/c not running,belt slipping	informed operation	08:40:00	08:50:00	
9	CHP	cc 54	eocr trips 9 times in overload	reset	07:00:00	13:00:00	
10	CHP	CC 51	mpd trips	reset	09:05:00	09:10:00	
11	CHP	CC 112,RG 3,CC 104,CC 105	no power,Dc supply failed in 1-141 LC2	fault acknowledge and reset, than charged all through CRP panel	08:30:00	08:55:00	
12	CHP	CC 36 S2	pending complaint pcrd cable	DNW jointed cable	06:00:00	11:00:00	
13	CHP	CC 38 SCR6	Lt not working,drive ol	reset	11:15:00	11:25:00	
14	WT	OP2	not moving fwd,d2 olr acted	reset	06:25:00	06:30:00	
15	WT	CP 3	not moving FWD,d3 olr acted	reset	11:15:00	11:20:00	
16	WT	OP1	not moving,D1 olr acted	reset	13:30:00	13:38:00	