



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 15/05/2025

Area: OHP

Equipment	Job
tt-1 on co-21	position sensor and plug, terminations were checked and kept in circuit
tt-3	chute position plugs were checked and tightness is ensured.
co-16	motor side ppm is done
tis on co-25	on feedback circuit is checked, temporarily bypassed CSR contact.
rsco-6a belt	control circuit is checked and tested in remote mode.
co-11a gallery	new ldb box is welded in position