



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/05/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	GALLERY SIEDE BRS BYPASS REQUEST	BYPASSED	20:00:00	20:10:00	
2	OHP	CO-28 BRC	BW-1 STOPPING ON ZSS	PROB ADJUSTED THEN TESTED	21:30:00	21:45:00	
3	CHP	CC-33 SCR-4	SLEW NOT WORKING	CONTROL SUPPLY RECYCLED	15:15:00	15:35:00	
4	CHP	CC-35 S-1	LT NOT WORKING	PCRD OVER TENSION .. RELEASED	15:35:00	15:45:00	
5	CHP	CC-33 SCR-4	BC STOPPING	ZSS CAGE TILTED ... FIXED PROPERLY	17:00:00	17:25:00	
6	CHP	CC-36 SCR-1	GVM SIDE BOOM POSITION NOT COMING	BYPASSED IN IO RACK	17:00:00	17:15:00	
7	CHP	CC-36 SCR-1	SLEW DRIVE TRIPPING	ONE MOTOR IR VALUE ZERO ... MOTOR DISCONNECTED ... OTHER SIDE MECH PROBLEM ... INFORMED TO MECH	18:10:00	19:00:00	SLEW OHP SIED MOTOR BURNT .. TO BE CHANGED
8	CHP	CC-32 SCR-5	LT NOT WORKING	DRIVE TRIPPED ON OL ... RESET DONE	19:00:00	19:20:00	
9	CHP	CC-39	DIRECT MODE REQ`	GIVEN AND REMOVED	19:25:00	21:25:00	
10	CHP	CC-13	STOPPING ON ZSS	CAGE PROBLEM ... BYPASSED ... SPARE CAGE KEPT ON SITE	19:20:00	19:30:00	CAGE NEEDS TO BE REPLACED



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/05/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC 203 FG SIGNAL IN 29	REQ FROM OPERATION	SIGNAL PROVIDED	20:30:00	20:45:00	
12	CHP	CC-54	TRIPPED ON OLR	RESET DONE	20:45:00	20:55:00	
13	WT	CP-1	COMMUNICATION PROBLEM	POWER RECYCLED IN PUSHER	15:30:00	15:40:00	
14	WT	CC-2 C/D	TRIPPED	RESET DONE	17:00:00	17:10:00	