



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/07/2025

Area: CHP

| Equipment | Job |
|-----------|--------------------------------------------------|
| CC 53 | BSS cable replaced and kept in ckt |
| CC 58 | Lighting improved |
| JH C 3 | Hoist panels maintenance was done |
| CC 26 | PPM was done |
| SCR 8 | Cable removal job under progress |
| CC 222 | VFD drive panel replaced and trail run was taken |