



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/05/2025

Area: IOSA

Equipment	Job
TBS	FAULTY PULL CHORD REMOVED FROM RIGHT BOOM CONVEYOR AND REPLACED WITH RECTIFIED PULLCHORD.
OC-18A	ZONE-3 PULLCHORDS and BELTSWAY SWITCHES FEEDBACK CHECKED AND COVERED WITH SHEETS.
OC-6A	LIGHTING DEFECTS RECTIFIED
OC-4A	FIELD DEVICES FEEDBACK AND INTERLOCK CHECKING DONE.