



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/01/2026

Area: CHP

| Equipment | Job |
|--------------------------|---|
| CM 19 | cleaning work done |
| CC 41 Chute vibrator | Base welding done and motor fixed. |
| CC 37 F/G | Motor overhauling done |
| LC 2 to LC 17 | Single strand Profibus cable replaced with multi strand |
| SCR 1,3 | 5 nos 30W lamp replaced |
| CC 105,108,31,33,112,223 | Running inspection and vibration done |
| CC 51,54 | PPM was done |