



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/05/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 26	Slew not working due to drive OLR acted	OLR reset done	03:20:00 23:50:00	03:40:00 00:10:00	
2	OHP	CO 35	OLR acted	reset done	23:35:00	23:45:00	
3	OHP	CO 28	BRS to be bypassed as per operation request	Bypassed in CJB	03:10:00	03:20:00	
4	OHP	CO 29 TIS	ZSS acted in running condition	Stone stuck up in pulley . cleaned , then ok	04:10:00	04:20:00	
5	OHP	CO 33M	OLR acted	reset done	05:00:00	05:10:00	
6	CHP	CC 54	Tripped in overload	reset done	00:15:00 02:50:00 03:00:00 04:55:00 05:05:00	00:20:00 02:55:00 03:05:00 05:00:00 05:10:00	
7	CHP	CC 131	Tripped in overload	reset done	01:45:00 02:50:00 04:20:00	01:50:00 02:55:00 04:25:00	
8	CHP	CC 117	Tripped in overload	reset done	02:20:00 03:25:00	02:35:00 03:40:00	
9	CHP	CC 48	Belt sway to be bypassed	Bypassed as per operation request	03:52:00	03:58:00	In IO rack
10	CHP	CC 34 , S-1	LT not working , drive tripped	Drive reset	23:15:00	23:30:00	
11	CHP	CC 36 , SCR 1	BC not running due to BSS acted	BSS released , informed to mechanical	00:15:00	00:30:00	
12	CHP	CC 39 , SCR 7	Slew not working	Found material jamming is there , informed operation for cleaning. After cleaning , slewing ok.	01:20:00	01:40:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 126	BSS acted	Bypassed	02:30:00	02:40:00	again kept in circuit at 6.10 am
14	CHP	CC 112, SCR 8	BC selection not showing in Reclaiming mode	PLC recycled, still problem. Reclaiming mode bypassed in programming	03:50:00	04:30:00	
15	CHP	CC 112, SCR 8	LT not working in remote mode	Checking going on. Kept in local and LT done	05:20:00	06:00:00	Informed to A shift
16	WT	OT 4	Drive 2 tripped on pgf 4 fault	reset done	22:55:00	23:00:00	
17	WT	OT 5	Drive not healthy due to OLF fault	Checked, material jamming on rollers. Informed to mechanical. After cleaning, ok	05:00:00	05:30:00	