



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/05/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 26	LT NOT TAKING PLACE PCRD O/T ACTED	RELESED	03:15:00	03:30:00	
2	OHP	TBS ON CO 19	LEFT LUFF NOT TAKING PLACE OLR ACTED	RESET	03:45:00	04:00:00	
3	OHP	CO 27A	MAIN CONTACTOR CHATTRING	ALL CONTROL WIRES TIGHTED	03:15:00	04:00:00	
4	CHP	CC 35 S1	LT NOT TAKING PLACE O/T ACTED	RELEASED	02:40:00	02:50:00	
5	CHP	CC 105 SCR 10	B/C NOT RUNNING C/S ACTED	PROBE CLEANING DONE	05:25:00	05:35:00	
6	WT	PO 5	F/W NOT MOVING D2 TRIPPED	RESET	23:40:00	23:50:00	COUPLING TIME