



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/12/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-32	B/C not running	E-PB acted.Released and tested okay	16:20:00	16:25:00	
2	OHP	CO-21	ZSS cage got reversed	Repositioned	19:10:00	19:25:00	
3	OHP	TBS on CO-21	LT not working	M-2 tripped.Made on	19:25:00	19:40:00	
4	CHP	CC-54	Reported tripped	OLR acted.Reset done(3 times)	16:54:00	20:16:00	
5	CHP	Cc-51	MPD acted	Feeding conveyor stopped.Reset done	20:16:00	20:20:00	
6	CHP	VS-3	Reported Tripped	OLR acted due to jamming	18:30:00	18:40:00	
7	CHP	CC-32	Reported tripped	OLR acted.Reset done	15:00:00	15:10:00	
8	CHP	Cc-33 SCR-5	Lt not taking place	Drive tripped.Reset done	16:30:00	16:40:00	
9	CHP	Cc-38 SCR-6	B/C not running	MPCB tripped.Motor meggered and found burnt.	18:10:00	22:30:00	Replacement is going on
10	CHP	CC-34 SCR-1	Skew not taking place	Limit acted due to coal jamming.	20:00:00	20:10:00	Informed to operation
11	CHP	CC-43	Reported tripped	OLR acted.Reset done	20:30:00	20:40:00	
12	WT	OP-5	Reported not moving	D5 tripped.Reset done	14:20:00	14:30:00	
13	WT	OC-1A	Reported tripped	OLR acted.Reset done	21:05:00	21:10:00	
14	IOSA	OC-7B	Reported ZSS acting	Cage stuck up with stone.Removed	14:35:00	14:45:00	