



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/06/2025

Area: OHP

Equipment	Job
CO-5,6,7,1A,JH-2	Lighting panel maintenance done
JH-3 to JH-4	Lighting done and rectification done
Day bin Compressor	Air Blaster phase fault rectification done
CO-49	Chute sensor earthing provided
CO-14A,14B,49	Hoist PPM done
WOBR ON CO-26	Brake panel shifting done and positioning and welding done
TBS-7 on CO-19	PPM done
CO-5A	PPM done
TBS-4 ON CO-5A	PPM done