



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 28	LT not taking place/stop pb operated at panel	pb released .	12:20:00	12:35:00	
2	OHP	tbs on co 22	lt not taking place/pcrd cable tension acted	cable tension released then ok	12:10:00	12:25:00	
3	OHP	brc on co 32	bc not running/olr acted	reset done	09:45:00	09:55:00	
4	OHP	TIS ON CO 29	zss bypass request from ope.	zss bypassed at module and feed back bypassed at i/o rack	12:50:00	13:00:00	
5	OHP	tbs on co 20	right luffing not taking place/drive tripped	reset done	09:15:00	09:30:00	
6	IOSA	tbs on 13a	communication problem	control wire loose at SMPS /tightend then ok	06:00:00	07:20:00	
7	IOSA	tbs on co 13a	cjd not getting reset	probe cleaning done then reset	06:00:00	06:15:00	