



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/02/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	slew not taking place,drive tripped	reset	03:05:00	03:20:00	
2	OHP	wobr on co 25	slew not working,crmp side,OLR acted	reset	03:30:00	03:45:00	
3	OHP	co 26	olr acted	reset	04:00:00	04:06:00	
4	CHP	CC 51	OLR acted	reset	23:30:00	23:35:00	3 times
5	CHP	CC 131	OLR acted	reset	03:45:00	03:50:00	
6	CHP	CC 39 SCR 6	LT not working,local emergency acted	emergency released	22:25:00	22:35:00	
7	CHP	CC 213 scr9	all drive not working,	PLC and wireless power recycle	00:45:00	00:55:00	
8	CHP	CC 40 SCR 2	slew not working,drive fault	reset	05:15:00	05:30:00	