



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/01/2026

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|----------------------------------|---|----------|----------|----------------------------|
| 1 | OHP | BRC on CO-28 | Reported B/W's not rotating | Oil level low | 08:45:00 | 09:00:00 | Informed to mechanical |
| 2 | OHP | CO-33M | Reported tripped | OLR acted.Reset done | 10:30:00 | 10:35:00 | |
| 3 | OHP | BRC on CO-33M | LT not taking place | PCRD tension acted.Released and tested okay | 11:30:00 | 11:40:00 | |
| 4 | OHP | BRC on CO-33M | Reported B/C stopping frequently | Chute sensor touching with chute plate.Bypassed due to operation requirement | 12:30:00 | 12:45:00 | To checked and put in line |
| 5 | OHP | CO-13(B/D) | Reported tripped | OLR acted.Reset done | 10:55:00 | 11:00:00 | |
| 6 | CHP | CC-108 | Reported tripped | OLR acted.Reset done(2 times) | 08:15:00 | 08:50:00 | |
| 7 | CHP | Cc-213 | Reported C/S acted | Acted due to coal and moisture mixture accumulation.Probe cleaned and tested okay | 09:30:00 | 09:40:00 | |