



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/09/2025

Incharge(s): Saurabh Kumar Yadav, Arnab Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--------------------------------|---|----------------------|----------------------|---------|
| 1 | OHP | WOBR on co 26 | slew not working drive tripped | reset | 18:15:00 | 18:30:00 | |
| 2 | OHP | VS 1A | olr acted | reset | 16:25:00 | 16:30:00 | |
| 3 | OHP | co 11(c) | tripped in overload | reset | 17:00:00 | 17:10:00 | |
| 4 | CHP | CC 40 | Luff not working | Air lock problem , informed to mechanical | 15:55:00 | 16:15:00 | |
| 5 | CHP | CC 46 | ZSS acted | holding nut tightened | 17:50:00 | 18:00:00 | |
| 6 | CHP | CC 126 | Chute sensor acted | module problem , replaced | 17:00:00 | 17:30:00 | |
| 7 | CHP | CC 40 , S-1 | Slew and hoist not working | slew 30 degree acted and luff up limit acted. Released limit, then ok | 19:30:00 20:30:00 | 20:00:00 20:50:00 | |
| 8 | CHP | CC 39 , SCR 3 | BC not working | arch chute not fixed properly | 20:10:00 | 20:30:00 | |