



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO21	Found ZSS module problem	ZSS bypassed	23:00:00	23:10:00	
2	OHP	BRC on CO32	BW 1 not working	Timer coil wire removed	23:15:00	23:20:00	
3	OHP	CO25	OLR acted 2 times	Reset done then ok	01:45:00 23:50:00	02:00:00 00:00:00	
4	OHP	CO26	OLR acted	Reset done	05:45:00	05:55:00	
5	OHP	BRC on CO33M	BW not running found oil temperature acted	Informed to A shift	05:00:00	06:00:00	
6	CHP	CC52	Over load acted	Reset done informed operation to clear load	03:45:00	03:55:00	