



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on Co 26	after shifting machine,power made on from LBDS 5 (panel no 6) but after 2 sec HT breaker tripped	I/C isolator having moisture due to which problem,in LBDS pnl no 6 put in test position and power feeding to isolator of CO 26 from loop isolator	23:40:00	00:05:00	i/c isolator made off and earthed
2	OHP	VS 1A	olr acted 2 times	reset	22:45:00	22:55:00	
3	OHP	TBS on CO 20	left/LUFF not taking place,olr acted	reset	23:00:00	23:15:00	
4	CHP	CC 29	OLR acted	reset	05:20:00	05:25:00	
5	CHP	CC 51	mpd acted	reset	04:20:00	04:25:00	
6	CHP	CC 114	motor tripped	reset	04:55:00	05:00:00	
7	WT	cp1	no movement,emergency not released by railway	released	04:30:00	04:50:00	