



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/08/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|--------------------|----------|----------|---------|
| 1 | OHP | co 16 | tripped in olr | reset | 12:40:00 | 12:45:00 | |
| 2 | OHP | CO 4A | reported red,pull chord operated | pc released | 07:30:00 | 07:40:00 | |
| 3 | OHP | CO 29 | OLR acted | reset | 08:20:00 | 08:30:00 | |
| 4 | OHP | CR 1 | not healthy,mpr acted | reset | 08:00:00 | 08:05:00 | |
| 5 | OHP | TBS on CO 23 | LT not taking place,track full jammed with flux | informed operation | 07:00:00 | 07:15:00 | |
| 6 | OHP | CO 35 | OLr acted | reset | 12:00:00 | 12:05:00 | |
| 7 | CHP | CC 33 | mpr trips due to olr | reset | 08:05:00 | 08:10:00 | 3 times |
| 8 | CHP | CC 33 scr 4 | b/ c stops in zss,,zss bypassed have loose connection | tightened | 08:20:00 | 08:25:00 | |
| 9 | CHP | CC 35 SCR 1 | LT not working,track jammed | informed operation | 08:20:00 | 08:30:00 | |
| 10 | CHP | CC 36 S2 | LT not working,pcrd cable fallen | pcrd cable winding | 09:00:00 | 09:15:00 | |
| 11 | CHP | CC 36 S2 | slew not taking place,slew limit acted | limit released | 09:00:00 | 09:15:00 | |
| 12 | CHP | CC 47 | zss not healthy,proximity sensor not properly adjusted | sensor adjusted | 10:00:00 | 10:10:00 | |
| 13 | CHP | cc 51 | mpd trips due to feeding conveyor olr | reset | 07:00:00 | 07:20:00 | 5 times |
| 14 | CHP | CC 54 | tripped in olr | reset | 09:20:00 | 09:25:00 | |
| 15 | IOSA | new wobr | LT not taking place, brake mpcb trips | made it on | 13:20:00 | 13:40:00 | |