



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/06/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35A , CO 37A	BRS to be kept in circuit as per operation request	kept in circuit	06:20:00	06:35:00	
2	OHP	CO 16	BRS to be kept in circuit as per operation request	kept in circuit	06:30:00	06:35:00	
3	OHP	CO 26	OLR acted	reset done	09:50:00	10:00:00	
4	OHP	CO 35A , CO 37A	BRS to be bypassed due to belt hole as per operation request	BRS bypassed at CJB	10:00:00	10:10:00	
5	OHP	CO 29	OLR acted	reset done	12:15:00	12:20:00	
6	OHP	CR 3	Motor protection relay acted due to overload	reset done	12:25:00	12:35:00	
7	OHP	WOBR on CO 26	LT not taking place due to end limit acted near feed table	reset done	12:10:00	12:35:00	
8	OHP	TBS on CO 22	LT not taking place	Drive tripped , reset done	13:10:00	13:20:00	
9	CHP	CC 38 , SCR 3	BC signal missing	LT done , PLC recycled. Still problem continue	08:30:00	09:00:00	Informed to gen shift. Antena and pigtail changed
10	CHP	CC 31	Tripped	Checked , material overload is there. Reset done and informed operation for cleaning + overload reset	11:10:00	12:50:00	
11	CHP	CC 105 , SCR 10	LT not working	Break MPCB tripping frequently . Outgoing isolated then healthy. Informed to gen shift	09:20:00	09:40:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/06/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 203	Frequently stopping on ZSS	ZSS probe fell down, adjusted properly	09:30:00	09:45:00	
13	CHP	CC 125	OLR acted	reset done	11:30:00	11:45:00	
14	CHP	CC 39	BRS to be bypassed as per operation request (due to insects)	bypassed at IO rack	11:51:00	11:57:00	
15	CHP	CC 32 , SCR 5	LT not working	M3 , M6 tripped . Made on	12:45:00	13:00:00	
16	CHP	CC 44	OLR acted	reset done	13:55:00	14:00:00	
17	CHP	CC 51	Tripped on overload	reset done	09:40:00	09:50:00	
18	CHP	CC 54	Tripped on overload	reset done	08:40:00	08:45:00	
19	CHP	CC 25	OLR acted	reset done	11:30:00	11:40:00	
20	WT	OP 9	No movement, Communication problem	Run in local mode, again kept in remote	08:20:00	08:50:00	
21	WT	OP 4	D-1 tripped on overload	reset done	13:25:00	13:35:00	