



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--------------------------------------|--------------------------------|----------|----------|---------|
| 1 | OHP | wobr on co 25 | slew not taking place,drive tripped | reset | 03:05:00 | 03:20:00 | |
| 2 | OHP | wobr on co 25 | slew not working,crmp side,OLR acted | reset | 03:30:00 | 03:45:00 | |
| 3 | OHP | co 26 | olr acted | reset | 04:00:00 | 04:06:00 | |
| 4 | CHP | CC 51 | OLR acted | reset | 23:30:00 | 23:35:00 | 3 times |
| 5 | CHP | CC 131 | OLR acted | reset | 03:45:00 | 03:50:00 | |
| 6 | CHP | CC 39 SCR 6 | LT not working,local emergency acted | emergency released | 22:25:00 | 22:35:00 | |
| 7 | CHP | CC 213 scr9 | all drive not working, | PLC and wireless power recycle | 00:45:00 | 00:55:00 | |
| 8 | CHP | CC 40 SCR 2 | slew not working,drive fault | reset | 05:15:00 | 05:30:00 | |