



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/12/2025

Area: CHP

| Equipment | Job |
|---|---|
| JH C 15,16 | Hoist panels maintenance was done |
| CC 12/13/15 | GPL point lighting improved by providing 120W and 2 nos 70W fixtures replaced |
| Coal complex | Rooms cleaning done |
| SCR 2 | Slew 30 degree limits kept in ckt |
| SCR 4 | Cabin top lamp fixture replaced |
| CCR road | One 120W LED fixture replaced |
| CC 107/108 | 70W SV fixtures provided |
| CC 31,33,37,38,40,42,43,45,104,107,125, SCR 2,4,5,6,7,9 | Running inspection was done and noted the defects |
| SCR 4 | PCRD motor brake adjusted |
| CC 39,40 | Feed table interlock ZSS cage relocated |
| CC 34,SCR 1,CC 105,SCR 10,CC 58, 58TT | PPM was done |