



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/11/2025

Area: CHP

Equipment	Job
CC 44	Running inspection was done
CC 107,126	Motor vibration readings noted
R 1	Luff down relay replaced and tested
SCR 6,9,10	Hydraulic motors greasing done
CC 204,205,206	Local trail taken after making the conveyor healthy
CC 201 to 211	PPM was done