



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset it done	00:35:00	00:45:00	
2	OHP	BRC on co 34	all drive not running,ACB off condition	acb made on	23:30:00	23:45:00	
3	OHP	TBS on co 21	LT not taking place,PCRD OT acted,overlapping of cable,guide problem	cable proper layering with mech	01:50:00	02:30:00	
4	OHP	CO 29	OLr acted	reset it done	03:00:00	03:10:00	
5	OHP	WOBR on co 26	all drives not running,acb is in off	acb made on	00:30:00	00:50:00	
6	OHP	BRC on co 32	LT not taking place,PCRD OT acted	OT released	02:15:00	02:25:00	
7	OHP	VS -5A	OLR acted	reset it done	02:00:00	00:21:00	
8	CHP	CC 32 SCR 5	LT not working,LT acted	OT released	22:45:00	22:55:00	
9	CHP	CC 36 SCR1	LT not taking place in reverse,end limit acted	machine moved fwd than ok	23:39:00	00:00:00	
10	CHP	CC 36 SCR1	slew not working,drive trips in overload,Tyre coupling got damaged	reset the drive,and informed mechanical	03:39:00	04:10:00	