



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 15/09/2025

Area: CHP

| Equipment | Job |
|-------------------------|--|
| CC 113 BSS | Two ckts earth fault isolated and made through |
| CC 113 LDB | RECTIFICATION DONE AND IMPROVED LIGHTING |
| LC 18,CM 19 | Transformer room and panel room cleaning done |
| CC 222/223 | Belt scale systems maintenance was done |
| CC 31 SCR 4 | ZSS and Boom position kept in ckt |
| JH C 210,211,CC 215 T/E | Pumps auto mode tested , rectified and trial taken |
| CC 37 HT coupler | Clamp fixed, cable taping done |
| CC 33,111,R1,S3 | PPM was done |