



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/07/2025

Area: CHP

Equipment	Job
CC 54/132 gallery	Lighting restored after rectifying cable problems
SCR 10	HT coupler hot blowing and maintenance done
SCR 10	Shifted to CC 106 and started cable removal
SCR 4	HT transformer maintenance done and charged supply