



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/09/2025

Area: OHP

Equipment	Job
BRC-4 ON CO-34	CRMP SIDE thruster brake problem is identified, shifted to hvmmc-1 for repair