



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 17/11/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR2A	RETURN FLOW INDICATION FAULT	RESET THEN OK	01:00:00	01:15:00	
2	OHP	CO 10A	OLR ACTED	RESET	05:25:00	05:30:00	
3	OHP	CC 27A ZSS ACTING	STONE STUCK IN ZSS CAGE	REMOVED	02:00:00	02:30:00	
4	OHP	CC 26	OLR ACTED	RESET	23:35:00	23:45:00	
5	OHP	WBR ON CO 29	B/C BELT SLIPPING	INFORMED TO OPRN	03:00:00	03:20:00	
6	OHP	WBR ON CO 29	B/W MCCB TRIP	MADE IT ON	05:30:00	05:40:00	
7	CHP	CC 117	OLR ACTED	RESET	03:20:00	03:35:00	
8	CHP	CC 131	OLR ACTED	RESET	01:20:00	01:25:00	
9	CHP	CC 45	OLR ACTED	RESET	00:30:00	01:00:00	5 TIMES
10	CHP	SCR 6 ON CC 38	LT DRIVE TRIPPED	RESET	02:10:00	02:20:00	
11	CHP	SCR 7 ON CC 37 LT	HT CABLE FELL UNDER WHEEL AND GOT CRUSHED	INFORMED TO DNW	03:00:00	03:30:00	INCOMER TRIPPED IN LBDS 5 MADE ON
12	CHP	SCR 9 ON CC 104	SLEW OLR ACTED	RESET	04:10:00	04:20:00	
13	WT	OT3	D1 TRIPPED ON ENCODER FAULT	RESET	05:35:00	05:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	IOSA	CC 25A ZSS ACTING	STONE STUCK IN ZSS CAGE	REMOVED THEN OK	23:00:00	23:15:00	