



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------|--|--|----------|----------|---------|
| 1 | OHP | CO 35 | OLR ACTED | RESET | 08:10:00 | 08:15:00 | |
| 2 | OHP | CC 54 | OLR ACTED (2TIMES) | RESET | 06:50:00 | 07:20:00 | |
| 3 | CHP | CC 131 | OLR ACTED (2TIMES) | RESET | 12:25:00 | 13:05:00 | |
| 4 | CHP | CC 51 | OLR ACTED | RESET | 12:10:00 | 12:20:00 | |
| 5 | CHP | CC 111 S 3 | B/C NOT RUNNING MAIN CONTACTOR COIL BURN | NEW 3TF50 CONTACTOR FIXED | 06:45:00 | 07:50:00 | |
| 6 | CHP | CC 33 SCR 4 | LT NOT TAKING PLACE PCRD GUIDE PROBLEM | INFORMED MECH ,proper winding done | 08:15:00 | 08:50:00 | |
| 7 | CHP | CC 39 scr7 | LT not working,OT acted | OT released | 09:35:00 | 10:00:00 | |
| 8 | CHP | CC 32 SCR 5 | LT not working,mpcb 2 tripped frequently | made it on | 09:50:00 | 13:30:00 | 8 times |
| 9 | CHP | CC 31 R1 | slew not working,,mechanical tyre coupling damaged | checked electrical side all ok,informed mech | 10:25:00 | 10:45:00 | |