



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/08/2025

Area: WT

| Equipment | Job |
|-----------------|--|
| OP 9 | New LOTUS Modem/Antenna installed both sides pusher and OT 5 ,found communication is OK |
| OT 5 | I/O panels blowing done |
| CP 3 | Bottom C and U clamps replaced and Trolley line inspection done, col no 39 bottom bus bar adjusted |
| CP 1 | Panel and motor side ppm done |
| OP 2,5 ,7 and 9 | after rake maintenance done |
| CP 1 and 3 | After rake maintenance done |