



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/08/2025

Area: OHP

Equipment	Job
VF 2A SPARE MOTOR	GRAESING DONE
CO 51	FESTOON CABLE REDRESSING DONE
TBS	SHIFTED FROM CO 22 TO CO 23
WBR1 ON CO 26	PCRD MOTOR REMOVED AND KEPT IN CM 18
BRC5 ON CO 34	CT LIMIT CABLE REPLACED
PROCESSOR B IN CHP	ALL PATCH CARDS REPLACED AND KEPT BACK IN RUN MODE