



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 09/08/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-10A(C/D)	Reported not moving	OLR acted.Reset done	23:10:00	23:15:00	
2	OHP	CO-11(B/D)	Reported not healthy	MPCB tripped.Reset done	23:50:00	00:00:00	
3	OHP	CO-11(C/D)	Reported not moving	MPCB tripped.Reset done	04:45:00	04:50:00	
4	CHP	CC-54	Reported not healthy	OLR acted. Reset done(4times)	02:50:00 04:10:00 04:30:00 04:45:00	02:55:00 04:15:00 04:35:00 04:50:00	
5	CHP	CC105 SCR-7	Reported LT not taking place	M2 and M6 MPCB Tripped due to track jamming.Reset done	03:28:00	03:40:00	Informed to operation
6	CHP	CC104 SCR-9	Pending from B shift.Slew and B/W not moving due to oil temperature high alarm	Air cooler and pump made on. Oil temperature came down and tested okay	22:00:00	22:36:00	
7	CHP	CC-35 SCR-1	Reported LT not taking place	M-7 tripped due to track jamming.Reset done	05:38:00	05:48:00	Informed to operation
8	WT	OP-6	Reported no movement	Emergency acted.Reset done	05:00:00	05:10:00	
9	WT	OC-1A	Reported ZSS acting	Checked and found material jamming	05:20:00	05:30:00	Informed to operation