



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/12/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	LT not taking place	PCRD OT acted.Released and tested okay	14:25:00	15:00:00	
2	OHP	BPC-1	ZSS acting	Probe gap adjusted and tested okay	16:00:00	16:10:00	
3	OHP	WOBR on CO-6A	B/C not running	OLR acted.Reset done	16:30:00	16:50:00	
4	OHP	WOBR on CO-6A	Luffing not working	Electrically okay.	16:30:00	16:50:00	Informed to mechanical
5	CHP	CC-33 SCR-3	Slew not working	Slew area jamming found	20:00:00	20:15:00	Informed to operation
6	CHP	CC-51	Reported tripped	MPD tripped.Feeding conveyor stopped(12 times)	15:30:00	21:30:00	
7	CHP	Cc-54	Reported tripped	OLR acted.Reset done(3times)	17:00:00	21:30:00	
8	CHP	CC-53 TT	Flap gate not working	OLR acted due to jamming.	17:15:00	17:20:00	
9	CHP	CC-117	Reported tripped	OLR acted.Reset done(2 times)	15:10:00	21:25:00	