



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 04/11/2025

Shift: C

Incharge(s): Nagendra Midde, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10 A(B)	not moving, zss acted due to PROBE TARGET DISTURBED	ADJUSTED, informed mech	23:30:00	23:45:00	
2	OHP	TBS on CO 7A	LT not working, boom reclaiming height not done	boom reclaiming height done	00:25:00	00:40:00	
3	OHP	BRC on CO 30	BC olr acted	reset	03:30:00	03:45:00	
4	OHP	TBS on CO 19	BC not running, due to jamming	informed operation	04:30:00	04:45:00	
5	OHP	BRC on CO 34	LT not working, PCRD OT acted	OT released	03:40:00	03:55:00	
6	OHP	BRC on CO 8A	BC olr acted	reset	05:00:00	05:15:00	
7	OHP	BRC on CO 30	b/w 2 not moving, gear wheel problem	informed mechanical	05:30:00	05:45:00	
8	CHP	scr 7 ON CC 37	LUFF OIL COOLING MOTOR TRIP	MADE IT ON	22:30:00	22:40:00	
9	CHP	SCR 7 ON CC 37	B/C OLR ACTED	RESET	05:05:00	05:20:00	
10	CHP	CC 51	mpd tripped 13 times	reset	00:05:00	05:35:00	
11	CHP	SCR 6 ON CC 38	LT M1, M2 TRIP DUE TO TRACK JAMMING	MADE IT ON	23:35:00	23:50:00	
12	CHP	CC 54	olr acted	reset	23:15:00	04:55:00	10 times



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/11/2025

Shift: C

Incharge(s): Nagendra Midde, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 125	OLR ACTED	RESET	03:15:00 04:35:00	03:20:00 04:40:00	
14	CHP	CC 28	OLR ACTED	RESET	01:30:00 02:30:00	01:40:00 02:40:00	
15	WT	op 9	no movement	wrong complaint	23:40:00	23:55:00	