



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/11/2025

Area: CHP

Equipment	Job
CC 44	Running inspection was done
CC 107,126	Motor vibration readings noted
R 1	Luff down relay replaced and tested
SCR 6,9,10	Hydraulic motors greasing done
CC 204,205,206	Local trail taken after making the conveyor healthy
CC 201 to 211	PPM was done