



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 03/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done	07:15:00	07:30:00	
2	OHP	CO-67	Reported tripped	OLR acted.Reset done	08:00:00	08:10:00	
3	OHP	TBS on CO-7A	Reported LT not taking place	Boom limit tied with rope and tested okay	08:00:00	08:10:00	
4	OHP	BRC on CO-28	Yard interlock problem	ZSS cage problem.Changed and tested okay	12:30:00	13:00:00	
5	OHP	TT-2 on Co-15	Reported Lt not taking place	One phase not coming to panel.Joints checked and found B-ph opened.Rejoint done and tested okay	06:00:00	08:10:00	
6	OHP	TIS-3 on CO-7	Reported tripped	OLR acted.Reset done	10:00:00	10:15:00	
7	CHP	CC-51	MPD tripped	Feeding conveyor stopped.Reset done(4 times)	07:46:00	10:41:00	
8	CHP	VF-30	Reported CJD acted	Probe cable got cut.Joint done and tested okay	10:50:00	11:30:00	Bypassed and again kept in line after rectification
9	CHP	VF-31	Reported not healthy	E-stop contact wire came out of TB.connected properly and tested okay	10:50:00	12:30:00	Bypassed and again kept in line after rectification
10	WT	CO-4(C/D)	Reported tripped	MPCB tripped.Reset done	11:05:00	11:10:00	