



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/08/2025

Area: WT

Equipment	Job
OP 10	New Modem/Antenna (LOTUS) installed ,tested OK
OP 10	Panel and motor side ppm done
CO 3 (BELT)	Ammeter replaced
OT 2 series	Panel and Motor side ppm done
CP 2 and 3	After rake maintenance done
OP 2,4 and 6	After rake maintenance done
LC 1	120W LED light fitting installed in front of main door