



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/10/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	DB-1	TRIPPED ON OLR (2TIMES)	RESET DONE	17:50:00 20:05:00	18:00:00 20:15:00	
2	OHP	BRC ON CO-8A	REPORTED ALL DRIVES ARE NOT RUNNING FOUND ACB TRIPPED	ACB MADE ON THAN OK	19:30:00	19:40:00	
3	OHP	VF-23	M1 TRIPPED ON OLR ... Y PHASE CUT IN MOTOR TB	CONNECTED ANDE TESTED	17:25:00	17:40:00	
4	OHP	CR-2	TRIPPED ON LOCKED ROTOR FAULT	RESET AFTER CLEANING	17:00:00	17:10:00	
5	CHP	CC-51	MPD TRIPPED (3TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	16:00:00	19:10:00	
6	CHP	CC-51	TRIPPED ON OLR (5TIMES)	RESET DONE	15:20:00	16:30:00	
7	CHP	CC-132	TRIPPED ON OLR	RESET DONE	19:55:00	20:00:00	
8	CHP	CC-54	TRIPPED ON OLR	RESET DONE	20:40:00	20:45:00	
9	CHP	CC-32 R-1	PLC FAULT	RESET	14:30:00	15:00:00	
10	CHP	CC-32	TRIPPED ON OLR	RESET DONE	16:35:00	16:40:00	
11	CHP	CC-107	TRIPPED ON OLR	RESET DONE	17:30:00	17:40:00	
12	CHP	CC-32 R-1	BC NOT RUNNING	ZSS PROB FIXED PROPERLY THEN TESTED	18:10:00	18:20:00	
13	CHP	CC-104 SCR-9	SLEW MCCB TRIPPED	RESET DONE	21:10:00	21:30:00	
14	IOSA	OC-25A	TRIPPED ON OLR TWICE	RESET DONE	15:30:00	16:00:00	