



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/06/2025

Area: OHP

Equipment	Job
co-5	schneider mpr is installed for co-5 and tested in decoupled condition.