



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/06/2025

Shift: C

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 1a	brs acted and not getting reset/fuse blown due to earth fault	bypassed at module	22:30:00	22:45:00	
2	OHP	co 34	tripped on olr9( eocr)	RESET DONE	23:50:00	23:59:00	
3	OHP	CO 29	TRIPPED ON THERMAL OLR	reset done	02:50:00	03:00:00	
4	CHP	cc131	tripped on olr	reset done	01:55:00 02:05:00	02:00:00 03:00:00	
5	CHP	cc 132	tripped on olr	reset done	03:20:00	03:25:00	
6	CHP	scr 4 on cc33	It not taking place	pcrd tension acted/reset done	22:50:00	22:59:00	
7	CHP	scr 1on cc36	slew not working/right limit acted	reset done	00:25:00	00:45:00	
8	CHP	scr 10 on cc 105	bc not running/olr acted	reset done	00:30:00	00:55:00	
9	CHP	scr 9 on cc104	bc not running/signal missing	It done then ok	01:55:00	02:05:00	
10	CHP	scr 5 on cc32	It not taking place/mpcb tripped	mpcb made on	03:25:00	03:35:00	
11	CHP	scr 1 on cc36	It not taking place/drive trip	reset done	04:55:00	05:08:00	
12	WT	op 9	f/reverse not taking place/communication problem	reset done	22:35:00	22:40:00	
13	WT	op 8	f/reverse not taking place/drive 4 tripped/error code showing	reset done	00:50:00	01:05:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/06/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	ot 5	not working/m1 tripped 3 times	reset done	03:50:00	04:00:00	
15	WT	cc2	B /D TRIPPED ON OLR	reset done	04:00:00	04:10:00	
16	WT	cp 2	F/R not taking place/communication problem	reset done	00:00:00	00:00:00	1040pm to 1045pm
17	WT	ot 5	m1 tripped due to jamming	reset done	04:30:00	04:40:00	