



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/05/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO34	OLR ACTED	RESET	11:00:00	11:10:00	
2	OHP	BF1A	STOPPING ON ZS	ZS PROBE GAP ADJUSTED THAN OK	13:40:00	14:00:00	
3	CHP	CC39 SCR 7	ADEPTER PROBLEM	ADEPTOR CHANGED THAN OK	07:10:00	07:25:00	
4	CHP	CC112 R1	SIGNAL MISSING	LT FORWARD MOVED THAN OK	06:40:00	07:00:00	
5	CHP	CC31 S3	LT NOT MOVING POWER AND OFF CONDITION	BOTH ARE MADE ON	10:40:00	11:00:00	
6	CHP	CC35 SCR 2	NOT SHOWING RECLAIMING MODE	PLC SUPPLY RECYCLE DONE	11:30:00	11:52:00	
7	CHP	CC35 SCR 2	SLEW NOT WORKING DRIVE TRIPPED	RESET	12:50:00	13:10:00	
8	CHP	CC44	OLR ACTED	RESET	12:00:00	12:10:00	
9	CHP	cc 39	OLR ACTED	RESET	13:35:00	13:45:00	
10	WT	OP 2	D1 OLR ACTED	RESET	07:50:00	08:00:00	