



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/11/2025

Area: WT

Equipment	Job
OT 4	Encoders and earthing removed for welding work, again fixed after work , tested.
OP 3	TOP ,C -clamp and one jumper ; Middle C and U clamps replaced
OP 3	All 3 nos bus bars adjusted by making slots to angles @ col no 97
OP 2 and 3	After Rake, maintenance done