



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/09/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TIS-4 ON CO-44	Reported not healthy	Bypassed as per operation requirement. checked and control problem rectified	18:00:00	20:00:00	to be kept in line after demand.NO delay
2	OHP	TBS ON CO-7A	Reported LT not moving	PCRD guide problem.Informed to mechanical	15:30:00	16:00:00	Guide adjustment done along with mechanical
3	CHP	CC-32 R-1	Reported B/C not running	Yard interlock ZSS probe problem. Probe changed and tested okay	15:00:00	15:40:00	
4	CHP	CC-40 SCR-3	Reported LT not taking place	PCRD overtension acted.Released and tested okay	16:05:00	16:25:00	
5	CHP	CC-37 SCR-7	LT not taking place	PCRD overtension acted.Released and tested okay	19:50:00	20:05:00	
6	CHP	CC-33 SCR-5	LT not taking place	Local emergency in acted condition.Released and tested okay	20:30:00	20:40:00	
7	CHP	CC-28	BRS (JOD) bent due to bobcat cleaning	Bent removed and kept in circuit	16:00:00	17:00:00	No delay
8	CHP	CC-51	Reported feeding conveyor tripped	MPD tripped. reset done	16:10:00 20:35:00	16:15:00 20:40:00	
9	CHP	RG-1	Tripped due to rotor jamming	Cleaning done and reset done	16:55:00	21:20:00	
10	WT	OP-3	Reported not moving	Checked and found collector pad damaged.Replaced and tested okay	18:00:00	19:00:00	No delay as rake wasnt there



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/09/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	WT	OP-10	Reported not moving	Checked and found breaker tripped in LC-2.Made on and tested okay	16:30:00	16:45:00	No delay as OT-5 under maintenance
12	IOSA	OC-18A	Reported not healthy	Control tripping in PLC.Earth fault in field devices found for OC-16A.OC-16A feeder kept off and OC-18A made healthy	20:45:00	21:10:00	