



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/07/2025

Area: OHP

Equipment	Job
co-5,9,6 brs	brs kept in circuit on operation request
co-69	schneider MPR is installed in place of CTMF relay.