



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 06/08/2025

Area: OHP

Equipment	Job
TT NEW MODEMS	POWER UP AND TESTING UNDER PROGRESS
CC 29	MOTOR VIBRATION READING TAKEN
CC 109	120W LIGHT FIXER DONE
CC 9	200 W FIXER GIVEN
CF1	CHUTE SENSOR RECTIFIED
JH2	LIGHTING RESTORED AND 1 200 W FIXED
CO 5, 8 9, 10, 15, 16	VIBRATION CHECKING DONE AND GREASING ALSO DONE
CO 4A	MOTOR AND PANEL SIDE PPM DONE
JH14	SPARE MOTORS BLOWING DONE
37 KW MOTOR	SHIFTED TO 30A HEAD END
CO 59, 62B ELT AND CARRIER DRIVE	MOTOR and panel ppm done