



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	TRIPPED ON OLR	RESET DONE	16:00:00	16:10:00	
2	OHP	WBR ON CO 25	LT NOT MOVING .. PCRD TENSION ACTED	RELEASED	15:35:00	15:45:00	
3	OHP	CO-25 WBR	LT M2 TRIPPED	RESET DONE AND BREAK ADJUSTED BY MECH	16:00:00	16:20:00	
4	OHP	CO-26	TRIPPED ON OLR	RESET DONE	16:45:00	16:55:00	
5	OHP	CO-33M BRC	BC NOT RUNNING ... CHUT SENSOR PROBLEM	BYPASS..ON INSTRUMENTATION AND OPR REQUEST	17:05:00	17:20:00	
6	OHP	CO-67	TRIPPED ON OLR	RESET DONE	20:35:00	20:40:00	
7	CHP	CC-103 TT	103 TO 105 TT POSITION NOT COMING	LOOSE IN IO RACK ... FIXED	20:00:00	20:20:00	
8	CHP	CC-51	TRIPPED ON MPR 6 TIMES	RESET DONE	16:50:00	21:40:00	
9	CHP	CC-131	TRIPPED ON OLR 4 TIMES	RESET DONE	17:30:00	21:30:00	
10	CHP	CC-51A	ZSS CAGE STONE STUCK	REMOVED	16:20:00	16:30:00	