



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------|--|------------|----------------------------------|----------------------------------|---------|
| 1 | OHP | CO-26 | TRIPPED ON OLR (3 TIMES) | RESET DONE | 00:30:00 03:00:00 22:50:00 | 00:40:00 03:05:00 23:00:00 | |
| 2 | OHP | WBR ON CO-29 | BC TRIPPED ON OLR | RESET DONE | 04:00:00 | 04:15:00 | |
| 3 | OHP | CO-111 | TRIPPED ON OLR | RESET DONE | 05:45:00 | 05:50:00 | |
| 4 | CHP | CC-31 SCR-4 | LT NOT WORKING PCRD OVER TENSION ACTED | RELEASED | 22:30:00 | 22:40:00 | |
| 5 | CHP | CC-32 SCR-5 | BC MPD ACTED ON OL | RESET DONE | 23:25:00 | 23:35:00 | |
| 6 | CHP | CC-202 AND CC 203 | TRIPPED ON OLR | RESET DONE | 23:50:00 | 00:05:00 | |
| 7 | CHP | CC-54 | TRIPPED ON OLR | RESET DONE | 04:05:00 | 04:10:00 | |
| 8 | CHP | CC-131 | TRIPPED ON OLR | RESET DONE | 00:30:00 | 00:35:00 | |
| 9 | CHP | CC-117 | TRIPPED ON OLR | RESET DONE | 23:03:00 | 23:18:00 | |
| 10 | CHP | CC-114 | TRIPPED ON OLR | RESET DONE | 05:05:00 | 05:15:00 | |
| 11 | CHP | CC -51 | TRIPPED ON OLR | RESET DONE | 05:05:00 05:20:00 | 05:10:00 05:25:00 | |
| 12 | CHP | CC-19 | TRIPPED ON OLR 2 TIMES | RESET DONE | 23:15:00 | 23:25:00 | |
| 13 | CHP | CC-39 SCR-6 | BC TRIPPED ON OLR | RESET DONE | 05:30:00 | 05:40:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|-------------------------------------|------------|----------|----------|---------|
| 14 | CHP | CC-54 | TRIPPED ON OLR | RESET DONE | 05:45:00 | 05:55:00 | |
| 15 | WT | CT-2 | INITIAL NOT CAME .. REV LIMIT STUCK | RELEASED | 02:30:00 | 02:40:00 | |